



2021 ANNUAL DRINKING WATER QUALITY REPORT

PWSID #: 4140083

NAME: Milesburg Borough Water Authority

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda. (This report contains important information about your drinking water. Have someone translate it for you, or speak with someone who understands it.)

WATER SYSTEM INFORMATION:

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Nick Witherite at (814) 355-4262. We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. They are held the 4th Monday of each month at 6:30 PM at the Milesburg Borough Building (416 Front Street).

SOURCE(S) OF WATER:

Our water source(s) is/are: (Name-Type-Location)

Bellefonte Borough Big Spring, a groundwater source from the Gatesburg Aquifer.

A Source Water Assessment of our source(s) was completed by the PA Department of Environmental Protection (Pa. DEP). The Assessment has found that our source(s) is/are potentially most susceptible to industrial activities, gas/service stations, fuel oil distributors, railroad yards, residential/light commercial activities, agricultural activities, airports, vehicle repair shops, industrial parks, Pennsylvania State University wastewater spray fields, on-lot waste disposal, pipelines – sewer, transportation corridors, landfills & dumps, RCRA – small quantity generators, and the drinking water treatment plant. Overall, our source(s) has/have moderate to high risk of significant contamination. A summary report of the Assessment is available on the Source Water Assessment Summary Reports eLibrary web page: www.elibrary.dep.state.pa.us/dsweb/View/Collection-10045. Complete reports were distributed to municipalities, water supplier, local planning agencies and PADEP offices. Copies of the complete report are available for review at the Pa. DEP North Central Regional Office, Records Management Unit at (570) 327-3636.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

MONITORING YOUR WATER:

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2021. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

DEFINITIONS:

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Minimum Residual Disinfectant Level (MinRDL) - The minimum level of residual disinfectant required at the entry point to the distribution system.

Level 1 Assessment – A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment – A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

Mrem/year = millirems per year (a measure of radiation absorbed by the body)

pCi/L = picocuries per liter (a measure of radioactivity)

ppb = parts per billion, or micrograms per liter (µg/L)

ppm = parts per million, or milligrams per liter (mg/L)

ppq = parts per quadrillion, or picograms per liter

ppt = parts per trillion, or nanograms per liter

DETECTED SAMPLE RESULTS:

Chemical Contaminants								
Contaminant	MCL in CCR Units	MCLG	Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Arsenic	10	0	0.202	-	ppb	12/18/18	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium	2	2	0.0264	-	ppm	12/18/18	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Mercury	2	2	0.098	-	ppb	12/18/18	N	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
Nitrate	10	10	1.9	-	ppm	06/14/21	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Dichloroacetic Acids (Five)	N/A	N/A	4.39	-	ppb	10/04/21	N/A	By-product of drinking water disinfection
Haloacetic Acids (Five)	60	N/A	4.39	-	ppb	10/04/21	N	By-product of drinking water disinfection
Chloroform (THM)	N/A	N/A	9.24	-	ppb	10/04/21	N/A	By-product of drinking water chlorination
Bromoform (THM)	N/A	N/A	0.67	-	ppb	08/26/20	N/A	By-product of drinking water chlorination
Bromodichloro-methane (THM)	N/A	N/A	5.82	-	ppb	10/04/21	N/A	By-product of drinking water chlorination
Chlorodibromo-methane (THM)	N/A	N/A	2.39	-	ppb	10/04/21	N/A	By-product of drinking water chlorination
Trihalomethanes	80	N/A	17.4	-	ppb	10/04/21	N	By-product of drinking water chlorination
Chlorine	MRDL = 4	MRDLG = 4	1.64	0.73-1.64	ppm	02/2021	N	Water additive used to control microbes

*EPA's MCL for fluoride is 4 ppm. However, Pennsylvania has set a lower MCL to better protect human health.

Entry Point Disinfectant Residual							
Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Chlorine	0.4	0.77	0.77-2.2	ppm	01/03/2021	N	Water additive used to control microbes.

Lead and Copper							
Contaminant	Action Level (AL)	MCLG	90 th Percentile Value	Units	# of Sites Above AL of Total Sites	Violation Y/N	Sources of Contamination
Lead	15	0	1.72	ppb	0	N	Corrosion of household plumbing systems; Erosion of natural deposits
Copper	1.3	1.3	0.063	ppm	0	N	Corrosion of household plumbing systems, Erosion of natural deposits; Leaching from wood preservatives

DETECTED CONTAMINANTS HEALTH EFFECTS LANGUAGE AND CORRECTIVE ACTIONS:

N/A

OTHER VIOLATIONS:

Samples for total trihalomethanes (TTHMs) and haloacetic acids (HAA5) should have been taken within three days of September 4, 2021. However, these samples were taken on September 23, 2021. A technical issue with the collected samples made it necessary to resample for TTHMs and HAA5, which was done on October 4, 2021. The results from the October 4, 2021 TTHM and HAA5 samples showed concentrations that were in compliance with applicable maximum contaminant levels. The next round of sampling for these contaminants is scheduled to occur within 3 days of September 4, 2022. A public notification of the late sampling is being provided with this report. The results of a weekly distribution system chlorine residual sample for July 2021 was not reported to the DEP within the acceptable time frame. Subsequent chlorine samples demonstrated acceptable disinfectant residual levels in the water distribution system.

EDUCATIONAL INFORMATION:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's *Safe Drinking Water Hotline* (800-426-4791).

Information about Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Milesburg Borough Water Authority is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the *Safe Drinking Water Hotline* or at <http://www.epa.gov/safewater/lead>.

OTHER INFORMATION:

The Authority continues to ask the customers to help conserve water and report any leaks, especially during a drought period. In addition, the Authority would like to remind all customers that any water meters that are located in unheated spaces are required to be protected from freezing by the customer. If you have any questions, please give the Authority a call. Water Authority Members: Fred Kellerman, Chairman; Plummer Davidson, Vice Chairman; Ethel Kellerman, Chuck Weidow, and Eric Fisher.



PUBLIC NOTICE

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER FAILURE TO MONITOR

**ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE
ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.**

Monitoring Requirements Not Met for Milesburg Borough Water Authority

Our water system violated several drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2021 we failed to monitor for the following contaminants and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, the required sampling frequency, how many samples we took, when samples should have been taken, and the date on which corrective action samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
Total Trihalomethanes	Annual	1	September 4, 2021 (+/- 3 days)	October 4, 2021
Haloacetic Acids	Annual	1	September 4, 2021 (+/- 3 days)	October 4, 2021

What happened? What was done? When will it be resolved?

Samples for total trihalomethanes (TTHMs) and haloacetic acids (HAA5) should have been taken within three days of September 4, 2021. However, these samples were taken on September 23, 2021. A technical issue with the collected samples made it necessary to resample for TTHMs and HAA5, which was done on October 4, 2021. The results from the October 4, 2021 TTHM and HAA5 samples showed concentrations that were in compliance with applicable maximum contaminant levels. The next round of sampling for these contaminants is scheduled to occur within 3 days of September 4, 2022.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information regarding this notice, please contact Nick Witherite at (814) 355-4262.

Certified by:

Signature: 

Date:

6-8-22

Print Name and Title:

Nicholas Witherite, Certified Water Operator

As a representative of the Public Water system indicated above, I certify that public notification addressing the above violation was distributed to all customers in accordance with the delivery requirements outlined in Chapter 25 PA Code 109 Subchapter D of the Department of Environmental Protection (DEP's) regulations. The following methods of distribution were used: _____

PWS ID#: 4140083

Date distributed:

6-27-22